

EC Declaration of Conformity

Document no. DZ.APT.ALW.Z2.ENG

Manufacturer: **APLISENS S.A.**,
ul. Morelowa 7, 03-192 Warszawa

We hereby acknowledge, that:

Smart pressure transmitters **APT-2000ALW** in all versions comply with directive

- **EMC – 2004/108/WE**

The following standard was applied PN-EN 61326-1:2006

Smart pressure transmitters **APT-2000ALW**
in Intrinsically Safe version comply with directive

- **ATEX – 94/9/WE**

Transmitters in Intrinsically Safe version are marked with the following certificate marking:


II 1/2G Ex ia IIC T4-T6 Ga/Gb
I M1 Ex ia I (version with housing material ss316)
II 1D Ex iaD 20 T105°C

Certificate no. FTZÚ 09 ATEX 0155

Certificate was issued by Notified Body no. 1026, Physical Technical Testing Institute,
Pikartska 7, 716 07 Ostrava Radvanice

The following standards were applied: EN 60079-0:2006, EN 60079-11:2007,
EN 503303:2000, EN 61241-0:2006, EN 61241-11:2006

Warsaw, 20th July 2009

Piotr Pawelec

Quality Manager