

EC Declaration of Conformity

Document no. DZ.LI.24.Z1.ENG

Manufacturer: **APLISENS S.A.**,
ul. Morelowa 7, 03-192 Warszawa

We hereby acknowledge, that:

Rail-mounted smart temperature transmitters **LI-24** in all versions comply with directive

- **EMC – 2004/108/WE**

The following standard was applied PN-EN 61326-1:2006

Temperature transmitters model **LI-24** in Intrinsically Safe version comply with directive

- **ATEX – 94/9/WE**

Transmitters in Intrinsically Safe version are marked with the following certificate marking:

II 1G Exia IIC T4/T5

I M1 Exia I


Certificate no. FTZU 08ATEX0160X

Certificate was issued by Notified Body no. 1026, Physical Technical Testing Institute,
Pikartska 7, 716 07 Ostrava Radvanice

The following standards were applied: PN-EN60079-0:2006, PN-EN60079-11:2007, PN-EN60079-26:2004, PN-EN50303:2000

Warsaw, 20th July 2009

Piotr Pawelec



Quality Manager