

EC Declaration

Document no. DZ.APC.APR..Z1

Manufacturer: **APLISENS S.A.,
ul. Morelowa 7, 03-192 Warszawa**

We hereby acknowledge, that:

Pressure transmitters **APCE-2000**, differential pressure transmitters **APRE-2000, APRE-2200, APRE-2000G, APRE-2000GN** in all versions comply with directive

- **EMC – 2004/108/WE**

The following standard was applied PN-EN 61326-1:2006

Pressure transmitters **APCE-2000**, differential pressure transmitters **APRE-2000, APRE-2200, APRE-2000G**

in Intrinsically Safe version comply with directive

- **ATEX – 94/9/WE**

Transmitters in Intrinsically Safe version are marked with the following certificate marking:

II 1/2G
Ga/Gb Ex ia IIC T4/T5/T6
I M1 Ex ia I

Certificate no. KDB 08ATEX282

Certificates were issued by Notified Body no. 1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.
The following standards were applied PN-EN60079-0:2006, PN-EN60079-11:2007, PN-EN60079-26:2007, PN-EN50303:2004.

Warsaw, 15th October 2009

Piotr Pawelec
P. Pawelec
Quality Manager